



# 中国国家强制性产品认证证书

证书编号：2021322310004028

认证委托人名称及地址  
可莱特电子(启东)有限公司  
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产者名称及地址  
可莱特电子(启东)有限公司  
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产企业名称及地址  
可莱特电子(启东)有限公司  
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

产品名称和系列、型号、规格  
火灾声光报警器  
SNES 系列

产品标准和技术要求  
GB/T 3836.1-2021、GB/T 3836.2-2021

上述产品符合《强制性产品认证实施规则 防爆电气》  
(CNCA-C23-01:2024)的要求，特发此证。  
发证日期:2026年05月08日 有效期至:2031年05月07日

首次发证日期:2021年05月31日  
认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，  
也可在认监委网站 ([www.cnca.gov.cn](http://www.cnca.gov.cn)) 查询。



批 准：



上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021322310004028

## NAME AND ADDRESS OF THE APPLICANT

Q light Electronics(Q idong) Co., Ltd.  
No.33, Haiyan Road, Q idong High-tech industrial development Zone, Q idong City,  
N antong City, Jiangsu Province, China

## NAME AND ADDRESS OF THE MANUFACTURER

Q light Electronics(Q idong) Co., Ltd.  
No.33, Haiyan Road, Q idong High-tech industrial development Zone, Q idong City,  
N antong City, Jiangsu Province, China

## NAME AND ADDRESS OF THE FACTORY

Q light Electronics(Q idong) Co., Ltd.  
No.33, Haiyan Road, Q idong High-tech industrial development Zone, Q idong City,  
N antong City, Jiangsu Province, China

## NAME, SERIES, MODEL AND SPECIFICATION

Fire Warning Light & Electric Horn Combinations  
SNES Series

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 3836.1-2021、GB/T 3836.2-2021

This is to certify that the above-mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date:2026-05-08 Valid until:2031-05-07

Date of initial issue:2021-05-31

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging in to the  
issuing authority's official website. It can also be inquired on the CNCA website ([www.cnca.gov.cn](http://www.cnca.gov.cn)).

(In case of dispute, the Chinese text shall prevail.)



APPROVAL:



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



# 中国国家强制性产品认证证书

证书编号：2021322310004028

证书附页：第 1 页 共 1 页

产品名称：  
火灾声光警报器

型号规格：  
SNESa-b  
a 代表型号，可为：无后缀（灯泡反射镜旋转型）、L（LED 长亮闪亮型）、  
LR（LED 反射镜旋转型）、S（频闪管爆闪型）；  
b 代表电压，可为：12（12VDC）、24（24VDC）、24/48（24VDC、  
48VDC）、120（120VAC）、230（230VAC）。

防爆标志：  
Ex db IIC T6 Gb

电气参数：  
U=12VDC 或 U=24VDC 或 24VDC~48VDC 或 120VAC 或 230VAC

相关报告编号：  
2021S17402-005387、2022S17402-008670

使用条件：  
1.特殊（限制）使用条件：  
1) 涉及隔爆接合面的维修须联系产品制造商。  
2) 隔爆接合面用紧固件的性能等级至少为 737N/mm<sup>2</sup>。  
3) 产品使用环境温度：-40℃~+60℃。  
2.外壳防护等级 IP66。

本页为证书附页，应与证书主页同时使用。



**SITIIS**  
Worldwide Access

批准：

郭友军



上海仪器仪表自控系统检验测试所有限公司