



中国国家强制性产品认证证书



证书编号：2021322310004028

认证委托人名称：可莱特电子(启东)有限公司
 认证委托人地址：江苏省南通市启东市启东高新技术产业开发区海燕路 33 号
 生产者名称：可莱特电子(启东)有限公司
 生产者地址：江苏省南通市启东市启东高新技术产业开发区海燕路 33 号
 生产企业名称：可莱特电子(启东)有限公司
 企业地址：江苏省南通市启东市启东高新技术产业开发区海燕路 33 号
 产品名称：火灾声光报警器
 系列、规格、型号：SNES 系列
 标准：GB/T 3836.1-2021、GB/T 3836.2-2021

认证模式：型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-G23-01:2019 《强制性产品认证实施规则 防爆电气》的要求，特发此证。产品相关信息详见附件。

发证日期：2022 年 11 月 22 日

有效期至：2026 年 05 月 30 日

首次发证日期：2021 年 05 月 31 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322310004028

APPLICANT: QLIGHT ELECTRONICS(QIDONG) CO.,LTD.
ADDRESS: 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE

MANUFACTURER: QLIGHT ELECTRONICS(QIDONG) CO.,LTD.
ADDRESS: 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE

FACTORY: QLIGHT ELECTRONICS(QIDONG) CO.,LTD.
ADDRESS: 33,HAIYAN ROAD,QIDONG HIGH-TECH INDUSTRIAL DEVELOPMENT ZONE,QIDONG,JIANGSU PROVINCE

PRODUCT: Fire Warning Light & Electric Horn Combinations
SERIES,SPECIFICATION,MODEL: SNES Series
STANDARDS: GB/T 3836.1-2021、 GB/T 3836.2-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:November 22, 2022 **Valid until:**May 30, 2026

Date of original certification:May 31, 2021

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:



 Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0006546



中国国家强制性产品认证证书



证书编号：2021322310004028

附 件

- 产品名称：** 火灾声光警报器
- 型号规格：** SNESa-b
a 代表型号，可为：无后缀（灯泡反射镜旋转型）、L（LED长亮闪亮型）、LR（LED反射镜旋转型）、S（频闪管爆闪型）；
b 代表电压，可为：12（12VDC）、24（24VDC）、24/48（24VDC、48VDC）、120（120VAC）、230（230VAC）。
- 防爆标志：** Ex db IIC T6 Gb
- 电气参数：** U=12VDC 或 U=24VDC 或 24VDC~48VDC 或 120VAC 或 230VAC
- 相关报告编号：** 2021S17402-005387、2022S17402-008670
- 使用条件：**
- 特殊（限制）使用条件：
 - 涉及隔爆接合面的维修须联系产品制造商。
 - 隔爆接合面用紧固件的性能等级至少为 737N/mm²。
 - 产品使用环境温度：-40℃~+60℃。
 - 外壳防护等级 IP66。

批 准：



上海仪器仪表自控系统检验测试所有限公司