



中国国家强制性产品认证证书

证书编号：2021322309004026

认证委托人名称及地址
可莱特电子(启东)有限公司
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产者名称及地址
可莱特电子(启东)有限公司
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产企业名称及地址
可莱特电子(启东)有限公司
江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

产品名称和系列、型号、规格
火灾声光报警器
SESA 系列

产品标准和技术要求
GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01:2024)的要求，特发此证。
发证日期:2026年05月08日 有效期至:2031年05月07日

首次发证日期:2021年05月31日
认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站 (www.cnca.gov.cn) 查询。



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2021322309004026

NAME AND ADDRESS OF THE APPLICANT

Q lightE lectronics(Q idong) Co., L td.
No.33, Haiyan Road, Q idong H igh-tech industrial developm ent Zone, Q idong C ity,
N antong C ity, Jiangsu Prov ince, China

NAME AND ADDRESS OF THE MANUFACTURER

Q lightE lectronics(Q idong) Co., L td.
No.33, Haiyan Road, Q idong H igh-tech industrial developm ent Zone, Q idong C ity,
N antong C ity, Jiangsu Prov ince, China

NAME AND ADDRESS OF THE FACTORY

Q lightE lectronics(Q idong) Co., L td.
No.33, Haiyan Road, Q idong H igh-tech industrial developm ent Zone, Q idong C ity,
N antong C ity, Jiangsu Prov ince, China

NAME, SERIES, MODEL AND SPECIFICATION

Fire W arning L ight & E lectric H om C om binations
SESA Series

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.31-2021

This is to certify that the above-mentioned product(s) complies with the requirements of
implem entation rules for com pulsory certification (CNCA-C23-01:2024).

Issue date:2026-05-08 Valid until:2031-05-07

Date of initial issue:2021-05-31

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging in to the
issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



APPROVAL:



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号：2021322309004026

证书附页：第 1 页 共 1 页

产品名称：
火灾声光警报器

型号规格：

SESA a-b-c

a 代表型号，可为：无后缀(灯泡反射镜旋转型)、L(LED长亮闪亮型)、LR(LED反射镜旋转型)、S(频闪管爆闪型)；

b 代表音调，可为：WS(警告音)、WP(特殊警告音)、WM(音乐音)、WA(提示音)、WV(声音信号)；

c 代表电压，可为：12(12VDC)、24(24VDC)、120(120VAC)、230(230VAC)。

防爆标志：

Ex db IIC T6 Gb、Ex tb III C T80°C Db

电气参数：

U=12VDC、24VDC、120VAC 或 230VAC

相关报告编号：

2022S17402-010407、2022S17402-008672、2021S17402-005385

使用条件：

1.特殊(限制)使用条件：

- 1) 涉及隔爆接合面的维修须联系产品制造商。
- 2) 隔爆接合面用紧固件的性能等级至少为 737N/mm²。
- 3) 产品使用环境温度：-40°C~+60°C。

2.外壳防护等级 IP66。

本页为证书附页，应与证书主页同时使用。



SITIIS
Worldwide Access

批准：

郭友军



上海仪器仪表自控系统检验测试所有限公司