



中国国家强制性产品认证证书

证书编号: 2025322309006530

认证委托人名称及地址

可莱特电子(启东)有限公司

江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产者名称及地址

可莱特电子(启东)有限公司

江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

生产企业名称及地址

可莱特电子(启东)有限公司

江苏省南通市启东市启东高新技术产业开发区海燕路 33 号

产品名称和系列、型号、规格

防爆声光报警器

QNES 系列

产品标准和技术要求

GB/T 3836.1-2021、GB/T 3836.2-2021

上述产品符合《强制性产品认证实施规则 防爆电气》

(CNCA-C23-01:2024)的要求, 特发此证。

发证日期:2025 年 03 月 28 日 有效期至:2030 年 03 月 27 日

首次发证日期:2025 年 03 月 28 日

认证模式:型式试验+初始工厂检查+获证后监督

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



SITIAs
Worldwide Access

批 准:

郭新华

上海仪器仪表自控系统检验测试所有限公司





中国国家强制性产品认证证书

证书编号: 2025322309006530

证书附页: 第 1 页共 1 页

产品名称:

防爆声光报警器

型号规格:

QNES-a b c

a 表示材质, 可为空缺 (铝合金外壳)、SUS (不锈钢外壳);

b 表示音调, 可为 WS(警告音)、WP(特殊警告音)、WM(音乐音)、WA(提示音)、WV(声音信号);

c 表示电压, 可为 12(12VDC)、24(24VDC)、120(120VAC)、230(230VAC)。

防爆标志:

Ex db II C T5/T6 Gb

电气参数:

U=12VDC、24VDC、120VAC 或 230VAC

相关报告编号:

2025S17402-015368

使用条件:

1.特殊(限制)使用条件:

- 1) 涉及隔爆接合面的维修须联系产品制造商。
- 2) 隔爆接合面用紧固件的屈服强度至少为 899N/mm²。
- 3) 产品使用环境温度: -40°C~+45°C(T6), -40°C~+60°C(T5)

2.产品外壳防护等级 IP66。


本页为证书附页, 应与证书主页同时使用。



SITIAS
Worldwide Access

批 准:

上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2025322309006530

NAME AND ADDRESS OF THE APPLICANT

Qlight Electronics(Qidong) Co., Ltd.
No.33, Haiyan Road, Qidong High-tech industrial development Zone, Qidong City,
Nantong City, Jiangsu Province, China

NAME AND ADDRESS OF THE MANUFACTURER

Qlight Electronics(Qidong) Co., Ltd.
No.33, Haiyan Road, Qidong High-tech industrial development Zone, Qidong City,
Nantong City, Jiangsu Province, China

NAME AND ADDRESS OF THE FACTORY

Qlight Electronics(Qidong) Co., Ltd.
No.33, Haiyan Road, Qidong High-tech industrial development Zone, Qidong City,
Nantong City, Jiangsu Province, China

NAME, SERIES, MODEL AND SPECIFICATION

Explosion Proof LED Signal Beacon Electronic Sounder Combination
QNES series

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 3836.1-2021、GB/T 3836.2-2021

This is to certify that the above-mentioned product(s) complies with the requirements of
implementation rules for compulsory certification (CNCA-C23-01:2024).

Issue date:2025-03-28 Valid until:2030-03-27

Date of initial issue:2025-03-28

Type of Certification: Type test + Initial inspection + Surveillance inspection

The certificate details and validity can be verified by scanning the QR code below or logging into the
issuing authority's official website. It can also be inquired on the CNCA website (www.cnca.gov.cn).

(In case of dispute, the Chinese text shall prevail.)



SITIAS
Worldwide Access

APPROVAL:



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.



中国国家强制性产品认证证书

证书编号: XXXXXXXXXXXXXXXXX

证书附页: 第 1 页 共 1 页

产品名称:

防爆声光报警器

型号规格:

QNES-a b c

a 表示材质, 可为空缺 (铝合金外壳)、SUS (不锈钢外壳);

b 表示音调, 可为 WS(警告音)、WP(特殊警告音)、WM(音乐音)、WA(提示音)、WV(声音信号);

c 表示电压, 可为 12(12VDC)、24(24VDC)、120(120VAC)、230(230VAC)。

防爆标志:

Ex db II C T5/T6 Gb

电气参数:

U=12VDC、24VDC、120VAC 或 230VAC

相关报告编号:

2025S17402-015368

使用条件:

1.特殊 (限制) 使用条件:

1) 涉及隔爆接合面的维修须联系产品制造商。

2) 隔爆接合面用紧固件的屈服强度至少为 899N/mm²。

3) 产品使用环境温度:

-40°C~+45°C(T6), -40°C~+60°C(T5)

2.产品外壳防护等级 IP66。

本页为证书附页, 应与证书主页同时使用。



SITIAS
Worldwide Access

批 准:

郭新华

上海仪器仪表自控系统检验测试有限公司